

REPORT OF TESTING




Independent Cabling Products Testing
Reference ITS Report Number 3030200-001, Dated September 11, 2002

Rendered To:

HCS (HES Cabling Systems)
Bankalar Caddesi Ekas Han No. 75-77
8000 Karakoy
Istanbul, TURKEY

SAMPLE DESCRIPTION:

Permanent Link (2 Connector)



| <u>Component ID</u> | <u>Manufacturer</u> | <u>Part Number</u> | <u>Description</u> |
|---------------------|---------------------|--------------------|--------------------|
| 1 | HCS | J6E-00813 | Telecom. Outlet |
| 2 | HCS | H6E-00401 | Horizontal Cable |
| 3 | HCS | P6E-02403-1u | Patch Panel |

Conclusions

- The Permanent Link Configuration, as described above, was independently tested by ITS/ETL Testing Laboratories in accordance with and to the requirements of ANSI/TIA/EIA 568-B.2-1 for Category 6 Cabling Systems, and was found to be in compliance with the indicated applicable requirements. All components were supplied by the manufacturer.

September 12, 2002

Robert Southworth
Laboratory Supervisor
Communications Products